



AF-E Series Enclosures

Discrepancy in AF-E Series Enclosure Certification

Ampcontrol advise we have recently identified a discrepancy in our certification document for the AF-E series enclosures in regard to the use of separately certified components, by listing "separately IECEx certified components", instead of "separately certified components" as provided on our other certifications.

We confirm that the equipment was in fact tested and certified with the separately certified Ex components, and as such confirm that this discrepancy presents no safety issue with any equipment supplied or in use, in no way detracts from the equipment's Explosion protection integrity and requires no action from customers or users of the equipment in this respect.

We confirm that on 16 September Ampcontrol requested the Certifying body to issue an updated certification statement through the formal supplementary certification process, to which they have confirmed will be provided to rectify the discrepancy.

In addition to this notice:-

Ampcontrol will provide a secondary statement for users with the supplementary application reference number, which we expect to receive in the near future.

Ampcontrol will provide a copy of the Supplementary Certificate upon receipt. Unfortunately at this early stage we are unable to provide a specific time frame however we will issue further advice as it becomes available.

Again we reiterate this is not a safety issue or problem with equipment in use, in no way detracts from the equipment's explosion protection integrity and requires no action from users in this regard at this time.

Ampcontrol recommends inclusion of this notice in your equipment safety file.

We trust this provides adequate clarification of any immediate concerns.

JOHN BLAYDEN

PRODUCT MANAGER - FLP

DISCLAIMER

While every effort has been made to assure the accuracy of this document at the date of issue, Ampcontrol assumes no liability resulting from any omissions or errors in this document, and reserves the right to revise content at any time.

Version No: 1	Doc No: / Name:	ENG NOTE AF-E Series Enclosures			
Status: APPROVED	19/09/2014	Author / SME Prepared by:	Tech Doc Officer	Approved by Process Owner:	Product Manager
					Page 1 of 1